



exceedences). (OR) Samples exceeded provincial water quality standards for the following parameters: (Use only the applicable portions of table below for which values have been exceeded).

Parameter	Limit MAC(mg/L)	Limit IMAC(mg/l)	Sample Results mg/l	#Samples exceeding Limit
Arsenic	0.010		0.0003	
Barium	1.0		0.0079	
Boron		5.0	0.3	
Bromate	0.01		N/A	
Cadmium	0.005		<0.00015	
fluoride	1.5		0.35	
Lead	0.01		0.0001	
Nitrate	45.0		<0.2	
Selenium	0.01		<0.00113	
Uranium	0.02		0.0117	

#### General Chemical

Parameter	Aesthetic Objectives *	Sample Results (mg/L)
Alkalinity	500	419
Bicarbonate	No Objective	511
Calcium	No Objective	149
Carbonate	No Objective	0
Chloride	250	17.4
Conductivity	No Objective	1457 us/cm
Hardness	800	706
Magnesium	200	81
PH	No Objective	7.8
Sodium	300	72
Sulphate	500	437.3
Total dissolved Solids	1500	1276

All waterworks serving less than 5000 persons are required to submit water samples for SE's General Chemical category once every two years if a ground water source and once per three months every second year if a surface water or blended surface/groundwater source. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as CaCO<sub>3</sub>), magnesium, sodium, sulphate and total dissolved solids.

\*Objectives apply to certain characteristics of or substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazards. The aesthetic objectives for several parameters (including hardness as CaCO<sub>3</sub>, magnesium, sodium and total dissolved solids) consider regional differences in drinking water sources and quality.

**More information on water quality and sample submission performance may be obtained  
from: Village of Montmartre**

**306-424-2040**

## Drinking Water Quality and Compliance

(Note: This short form may be used for communities or waterworks serving a population of less than 5000).

### Introduction

The Water Security Agency and the Ministry of Environment requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister's Order or Permit to Operate a waterworks. The following is a summary of the (Montmartre ) water quality and sample submission compliance record for the 2022 time period. This report was completed on January 3, 2023 (must be completed before June 30 each year on a calendar year based reporting frequency). Readers should refer to Water Security Agency's Municipal Drinking Water Quality Monitoring Guidelines, June 2015, EPB 502 for more information on minimum sample submission requirements and the meaning of type of sample. Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, "what is the significance of Selenium in a water supply", more detailed information is available from: [http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index\\_e.html](http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index_e.html).

### Water Quality Standards

#### Bacteriological Quality

##### Parameter/Location Limit

		Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform	0 Organisms/100mL	36	34	0
E. Coli	0 Organism/100mL	36	34	0

#### Water Disinfection –

##### Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	#Tests Required	# Tests Required	Adequate Chlorine(%)
Chlorine Residual	0.1mg/L free OR 0.5mg/L	0.49-2.07	0.16-1.74	24	24	100%

#### Water Disinfection - Free Chlorine Residual for Water Entering Distribution System from Waterworks Records From Water Treatment Plant Records

Parameter	Limit (mg/L)	Test Level Range	#Tests Performed	Tests not meeting Requirements
Free Chlorine Residual	At least 0.10	0.12-2.26	365	0

A minimum of 0.10 milligrams per litre (mg/L) free chlorine residual is required for water entering the distribution system. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.10 mg/L free chlorine residual.

#### Turbidity – From Water Treatment Plant Records

Parameter	Limit NTU	Test Level Range	#of Tests not meeting Requirements	Maximum Turbidity	#Tests Required	#Tests Performed
		0.06-0.90	0	0.90	365	365

#### Chemical – Health Category

All waterworks serving less than 5000 persons are required to submit water samples for SE's Chemical Health category once every 2 years. The Chemical Health category includes analysis for arsenic, barium, boron, cadmium, chromium, fluoride, lead, nitrate, selenium and uranium.

The last sample for Chemical Health analysis was submitted on December 5 2022. Sample results indicated that the provincial drinking water quality standards were not exceeded. (Use this one if review indicates that there were no